

## Short Form Classification Report Nr. 15279G

- 1 - Classification report reference and date  
15279E written in English: 22-12-2011
- 2 - Sponsor of the report : **Dupont De Nemours**
- 3 - Testing lab : Warringtonfiregent (WFRGENT nv)
- 4 - Standard :  
For testing: EN ISO 11925-2 (2010) and EN 13823 (2010)  
For classification: EN 13501-1+A1: 2009
- 5 - Tested product : **Corian® Custom Grade**
- 6 - Classification : **B-s1, d0**
- 7 - Field of application :

- Substrate: Euroclass D-s2, d0 or better with a nominal thickness of at least 10mm and a nominal density of at least 510 kg/m<sup>3</sup>
- Without an airgap
- Fixing: Directly glued onto the substrate with silicone (190 g/m<sup>2</sup>)
- Without joints

This classification is valid for the following product parameters:

- Nominal thickness: all thicknesses between or equal to 6mm and 12mm
- Nominal density: 1750 kg/m<sup>3</sup>
- Colour: The colours Glacier White, Bone, Vanilla, Glacier Ice, Bisque, Designer White, Cameo White and all colours with a calorific value lower than or equal to 9,9 MJ/kg

Ghent, 22 DEC. 2011



I. LAMMERTYN  
Project Assistant



ir. K. CATRY  
Project Leader

*This short form classification report has been drafted according to EGOLF regulation R4 "Application note: clause 5.10 [5.10/1] – Issue 01- 2002-06-21 – Types of test reports used in fire testing" Whilst the test data and classification provided within this short report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2 (2010), EN 13823 (2010), EN ISO 1716 (2010) and EN 13501-1+A1:2009, the presentation of the results in this short form may not satisfy the requirements of that standard and EN ISO/IEC 17025: 2005. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted. The full classification report Nr. 15279E is available from Dupont De Nemours.*

This document is the original version of this report and is written in English. This report may be used only literally and completely for publications. - For publications of certain texts, in which this report is mentioned, our permission must be obtained in advance.