

## Short Form Classification Report No. 15279H

- 1 - Classification reports, reference and date  
**15279E and 14825C** written in English: 22-12-2011 and 04-04-2011
- 2 - Sponsor of the report: **Du Pont de Nemours**
- 3 - Testing lab: Warringtonfiregent (WFRGENT nv)  
*Accredited laboratory: see accreditation scope on the website  
(<http://www.wfrgent.com/en/>)*
- 4 - Standard:  
For testing: EN ISO 11925-2 (2010/AC:2011) and EN 13823 (2010)  
For classification: EN 13501-1:2007+A1:2009
- 5 - Tested product: **Corian® Custom Grade** (produced in Turkey)
- 6 - Classification: **B-s1,d0**
- 7 - Field of application:

Classification report No. 15279E

- Substrate: Euroclass D-s2,d0 or better with a nominal thickness of at least 10 mm and a nominal density of at least 510 kg/m<sup>3</sup>
- Without an airgap
- Fixing: Directly glued onto the substrate with silicone (190 g/m<sup>2</sup>)

This classification is valid for the following product parameters:

- Nominal thickness: All thicknesses between or equal to 6 mm and 12 mm
- Nominal density: 1750 kg/m<sup>3</sup>
- Colour: The colours Glacier White, Bone, Vanilla, Glacier Ice, Bisque, Designer White, Cameo White and all colours with a calorific value lower than or equal to 9,9 MJ/kg

Classification report No. 14825D

- Substrate: Euroclass A2-s1,d0 or better with a nominal thickness of at least 9 mm and a nominal density of at least 652,5 kg/m<sup>3</sup>
- Without an airgap
- Fixing: Hung onto a suspension frame consisting of vertical and horizontal bars of aluminium, through a C-profile. The horizontal bars were screwed onto the substrate by coupling clips.

This classification is valid for the following product parameters:

- Nominal thickness: 12 mm
- Nominal density: 1750 kg/m<sup>3</sup>
- Colour: Glacier White

SIGNED

APPROVED

*This short form classification report has been drafted according to EGOLF agreement EGA 08rev:2012. "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2 (2010/AC:2011), EN 13823 (2010) and EN 13501-1:2007+A1:2009, the presentation of the results in this short form may not satisfy the requirements of that standard and EN ISO/IEC 17025: 2005/AC: 2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted. The full classification reports No. **15279E** and **14825C** are available at **Du Pont de Nemours**.*

This document is the original version of this document and is written in English. This document may be used only literally and completely for publications. - For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.