

## Short Form Classification Report No. 16275K

- 1 - Classification report reference and date  
**16275F** written in English: 07-02-2014
- 2 - Sponsor of the report: **Du Pont de Nemours**
- 3 - Testing lab: Warringtonfiregent (WFRGENT nv)  
*Accredited laboratory: see accreditation scope on the website  
(<http://www.wfrgent.com/en/>)*
- 4 - Standard:  
For testing: EN ISO 11925-2 (2010/AC:2011) and EN 13823 (2010)  
For classification: EN 13501-1:2007+A1:2009
- 5 - Tested product: **Corian® Deep colour**
- 6 - Classification: **B-s1,d0**
- 7 - Field of application:
  - Substrate: Euroclass A2-s1,d0 or better with a nominal thickness of at least 9 mm and a nominal density of at least 652,5 kg/m<sup>3</sup>
  - Without a void
  - Fixing: Directly glued onto the substrate with Fix all high tack glue (Soudal) with a PCS value lower than or equal to 2,87 MJ/m<sup>2</sup>.

This classification is valid for the following product parameters:

- Nominal thickness: 12 ± 0,6 mm
- Nominal density: 1680 kg/m<sup>3</sup> – 1750 kg/m<sup>3</sup>
- Colour: All deep colours with a PCS value lower than or equal to 10,1 MJ/kg

The following colours are included:

- Deep Anthracite
- Deep Nocturne
- Deep Sable
- Deep Espresso

SIGNED

APPROVED

*This short form classification report has been drafted according to EGOLF agreement EGA 08rev:2012 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2 (2010/AC:2011), EN 13823 (2010) and EN 13501-1:2007+A1:2009, the presentation of the results in this short form may not satisfy the requirements of that standard and EN ISO/IEC 17025: 2005/AC: 2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted. The full classification report No. 16275F is available at **Du Pont de Nemours**.*

This document is the original version of this document and is written in English. This document may be used only literally and completely for publications. - For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.